

# COFFS HARBOUR LABORATORY

## Environmental Analysis

Page 1 of 1



STUARTS POINT CONVENTION CENTRE  
GLENNHOUSSENLOGE  
250 GRASSY HEAD ROAD  
STUARTS POINT NSW 2441

BATCHNUMBER: 22/1690  
No. of SAMPLES: 1  
DATE COLLECTED: 22/08/22  
DATE RECEIVED: 22/08/22  
TIME RECEIVED: 13:45  
DATE TESTING COMMENCED:  
22/08/22

### REPORT OF ANALYSIS

SAMPLE REFERENCE	SAMPLE DESCRIPTION
22/1690/1	STUARTS POINT CONVENTION CENTRE EFFLUENT

ANALYSIS	UNITS	22/1690/1			METHOD NO
pH	pH unit	7.4			APHA 4500-H+ B
Total Suspended Solids	mg/L	13			APHA 2540 D
Biochem Oxygen Demand (BOD5)	mg/L	8			APHA 5210 B
Thermotolerant Coliforms	cfu/100mL	75			ELM 3
Total Nitrogen	mg/L	13.7			EL30F
Total Phosphorus	mg/L	0.76			EL18F

#### Comments

Sample(s) collected by client and analysed as received in accordance with "Standard Methods for the Examination of Water & Wastewater", 23rd Edition, 2017, APHA. Raw data sheets stating analysis dates are available upon request.

Tests marked with '#' are not covered by NATA Accreditation.

Note: Microbiological results are membrane presumptive.

Measurement Uncertainty is available upon request.

Thermotolerant Coliforms are equivalent to Faecal Coliforms.

Report Date: 29/08/22



Accredited for compliance with ISO/IEC 17025 - Testing  
[Accreditation Numbers: 12359 (Chemical) & 14565 (Microbiological)]

Approved:

Shane Ewart  
Technical Supervisor  
Microbiology and Chemistry

The results of the tests, calibrations and/or measurements included in this document are traceable to Australia