

COFFS HARBOUR LABORATORY

Environmental Analysis

Page 1 of 1



YARRA ADVENTURE & HOLIDAY PARK
TREVOR TOOMEY
250 GRASSY HEAD ROAD
STUARTS POINT NSW 2441

BATCH NUMBER: 24/0541
No. of SAMPLES: 4
DATE COLLECTED: 28/02/24
DATE RECEIVED: 28/02/24
TIME RECEIVED: 13:35
DATE TESTING COMMENCED:
28/02/24

REPORT OF ANALYSIS

SAMPLE REFERENCE	SAMPLE DESCRIPTION
24/0541/1	EFFLUENT 1
24/0541/2	EFFLUENT 2
24/0541/3	EFFLUENT 3
24/0541/4	EFFLUENT 4

ANALYSIS	UNITS	24/0541/1	24/0541/2	24/0541/3	24/0541/4	METHOD NO
pH	pH unit	7.7	7.7	7.4	7.2	APHA 4500-H+ B
Total Suspended Solids	mg/L	49	49	74	27	APHA 2540 D
Biochem Oxygen Demand (BOD5)	mg/L	20	17	14	7	APHA 5210 B
Thermotolerant Coliforms	cfu/100mL	6,900	415	225	445	ELM 3
Total Nitrogen	mg/L	18.3	8.01	7.13	2.98	EL30F
Total Phosphorus	mg/L	5.13	2.69	1.61	0.63	EL18F

Comments

Sample(s) collected by client and analysed as received in accordance with "Standard Methods for the Examination of Water & Wastewater", 24th Edition, 2022, APHA. Raw data sheets stating analysis dates are available upon request.

Tests marked with '#' are not covered by NATA Accreditation.

Note: Microbiological results are presumptive.

Measurement Uncertainty is available upon request.

Report Date: 6/03/24



Accredited for compliance with ISO/IEC 17025 - Testing
Accreditation Number: 12359

Approved:

Shane Ewart
Technical Supervisor
Microbiology and Chemistry

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.