

COFFS HARBOUR LABORATORY

Environmental Analysis

Page 1 of 1



YARRA ADVENTURE & HOLIDAY PARK
WILLIAM PULLEN
250 GRASSY HEAD ROAD
STUARTS POINT NSW 2441

BATCH NUMBER: 25/1255
No. of SAMPLES: 1
DATE COLLECTED: 29/05/25
DATE RECEIVED: 29/05/25
TIME RECEIVED: 14:54
DATE TESTING COMMENCED:
29/05/25

REPORT OF ANALYSIS

SAMPLE REFERENCE	SAMPLE DESCRIPTION
25/1255/1	EFFLUENT

ANALYSIS	UNITS	25/1255/1			METHOD NO
pH	pH unit	7.3			APHA 4500-H+ B
Total Suspended Solids	mg/L	12			APHA 2540 D
Biochem Oxygen Demand (BOD5)	mg/L	10			APHA 5210 B
Thermotolerant Coliforms	cfu/100mL	35			ELM 3
Total Nitrogen	mg/L	14.4			EL30F
Total Phosphorus	mg/L	1.30			EL18F

Comments

Sample(s) collected by client and analysed as received in accordance with "Standard Methods for the Examination of Water & Wastewater", 24th Edition, 2023, APHA. Raw data sheets stating analysis dates are available upon request.

Tests marked with '#' are not covered by NATA Accreditation.

Measurement Uncertainty is available upon request.

Report Date: 4/06/25



Accredited for compliance with ISO/IEC 17025 - Testing
Accreditation Number: 12359

Approved:

Shane Ewart
Technical Supervisor
Microbiology and Chemistry

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.